



KLEENFUEL

FUEL FILTRATION UNIT TEST RESULTS



Doc Code: HCS-IMS-MD-06/Rev.1/Mar2016

Kleenoil Middle East

Exclusive Kleenoil Agent in Oman, Qatar, Saudi Arabia,
United Arab Emirates and Malaysia



KLEENOIL

Kleenoil Middle East

FUEL UNIT TEST RESULTS

This document presents the results of testing the Kleenfuel Filtration Unit onboard an offshore construction support vessel. It aims to show the amount of savings on fuel consumption of one generator along with the reduction of its various toxic gas emissions.

The test was conducted on a Volvo Penta D16 generator at 15% load with and without the Kleenfuel filtration unit installed. The test ran for sixty (60) minutes and was repeated five (5) times for each configuration (with and without the Kleenfuel unit). The exhaust gas emissions were measured using the Kane Auto 5-4 gas analyser.

The subject vessel is owned by our client, a service provider to the offshore oil and gas industry operating in the UAE and Middle East.



**Reduce Fuel
Consumption
by 9%***



**Reduce
Exhaust Gas
Emission**



**Spend less
on Fuel**

a. With Kleenfuel Filtration Unit

Test No.	Ave. Load on Generator	Duration of Test (minutes)	Ave. Consumption per Hour	HC (ppm)	CO (%)	CO ₂ (%)	NO (%)	O ₂ (%)
1	92	60	16.10	0	0.02	3.10	117.00	20.79
2	93	60	16.20	1	0.02	2.80	89.00	19.92
3	91	60	16.00	0	0.03	3.30	93.00	20.47
4	93	60	16.30	1	0.03	3.40	104.00	19.62
5	92	60	16.20	1	0.03	3.20	111.00	18.21
Average	92.2	60	16.20	1	0.03	3.16	102.80	19.80

b. Without Kleenfuel Filtration Unit

Test No.	Ave. Load on Generator	Duration of Test (minutes)	Ave. Consumption per Hour	HC (ppm)	CO (%)	CO ₂ (%)	NO (%)	O ₂ (%)
1	91	60	17.70	13	0.07	10.60	754.00	22.34
2	92	60	17.50	12	0.07	10.60	724.00	21.45
3	92	60	18.10	15	0.09	10.80	913.00	23.15
4	90	60	17.80	13	0.08	10.70	902.00	22.97
5	92	60	17.40	11	0.08	10.80	891.00	22.66
Average	91.4	60	17.70	13	0.08	10.70	836.80	22.51

+ Summary of Kleenfuel Filtration Unit Test

	Fuel Consumption	HC (ppm)	CO (%)	CO ₂ (%)	NO (%)	O ₂ (%)
Without KleenFuel Unit	17.70	13	0.08	10.70	836.80	22.51
With KleenFuel Unit	16.20	1	0.03	3.16	102.80	19.80
Difference	1.54	12	0.05	7.54	734.00	2.71
Savings in Percentage*	8.70%	95%	66.67%	70.47%	87.72%	12.05%

***These results are from the generator having only 15% load during testing. It is to be expected that savings in percentage would result to even much higher numbers when the generator is efficiently loaded at 70%.**

Abbreviations:

HC = Hydrocarbon

NO = Nitrogen Oxide

CO₂ = Carbon Dioxide

CO = Carbon Monoxide

O₂ = Oxygen

Savings with Kleenfuel Filtration Unit

The test results shows that with Kleenfuel Filtration Unit, the fuel consumption of the generator is lesser and is reduced by 9%. Because of this, it is now possible to spend less on fuel!

Furthermore, the gas emissions are also reduced significantly with the hydrocarbon emissions being 95% less and the carbon dioxide being 70% less than the generator running without the Kleenfuel Filtration Unit.



The KleenFuel Filtration Unit bring significant financial savings and huge positive impact towards the environment - truly an efficient, cost-effective and green solution!

Be a more **sustainable** and **profitable** business now with
Kleenoil Middle East!



Kleenoil Middle East

c/o HCS Hydrocarbon Solutions LLC
PO Box 37275
Unit 327 Mina Port Warehouses
Abu Dhabi, United Arab Emirates
Tel: +971 2 6771595
Fax: +971 2 6773625

Contact Person: Johann Louw
Mobile: +971 56 1296025
Email: johann@kleenoilme.com
Website: www.kleenoilme.com



www.kleenoilme.com